

# Energy performance certificate (EPC)

2 Hope Cottages  
Winchester Road  
Waltham Chase  
SOUTHAMPTON  
SO32 2LL

Energy rating

F

Valid until: **25 September 2032**

Certificate number: **3032-5621-7200-0637-0222**

Property type

Semi-detached house

Total floor area

65 square metres

## Rules on letting this property



### You may not be able to let this property

This property has an energy rating of F. It cannot be let, unless an exemption has been registered. You can read [guidance for landlords on the regulations and exemptions](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance) (<https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance>).

Properties can be let if they have an energy rating from A to E. The [recommendations section](#) sets out changes you can make to improve the property's rating.

## Energy efficiency rating for this property

This property's current energy rating is F. It has the potential to be B.

[See how to improve this property's energy performance.](#)

Score	Energy rating	Current	Potential
92+	A		
81-91	B		86   B
69-80	C		
55-68	D		
39-54	E		
21-38	F	23   F	
1-20	G		

The graph shows this property's current and potential energy efficiency.

Properties are given a rating from A (most efficient) to G (least efficient).

Properties are also given a score. The higher the number the lower your fuel bills are likely to be.

For properties in England and Wales:

the average energy rating is D  
the average energy score is 60

## Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says "assumed", it means that the feature could not be inspected and an assumption has been made based on the property's age and type.

Feature	Description	Rating
Wall	Solid brick, as built, no insulation (assumed)	Very poor
Wall	Cavity wall, as built, no insulation (assumed)	Poor
Roof	Pitched, 250 mm loft insulation	Good
Window	Fully double glazed	Average
Main heating	Room heaters, electric	Very poor
Main heating control	No thermostatic control of room temperature	Poor
Hot water	Electric immersion, standard tariff	Very poor
Lighting	No low energy lighting	Very poor
Floor	Solid, no insulation (assumed)	N/A
Secondary heating	Room heaters, electric	N/A

### Primary energy use

The primary energy use for this property per year is 521 kilowatt hours per square metre (kWh/m<sup>2</sup>).

### Additional information

Additional information about this property:

- Cavity fill is recommended
-

## Environmental impact of this property

This property's current environmental impact rating is F. It has the potential to be B.

Properties are rated in a scale from A to G based on how much carbon dioxide (CO<sub>2</sub>) they produce.

Properties with an A rating produce less CO<sub>2</sub> than G rated properties.

An average household produces 6 tonnes of CO<sub>2</sub>

This property produces 5.7 tonnes of CO<sub>2</sub>

This property's potential production 0.8 tonnes of CO<sub>2</sub>

By making the [recommended changes](#), you could reduce this property's CO<sub>2</sub> emissions by 4.9 tonnes per year. This will help to protect the environment.

Environmental impact ratings are based on assumptions about average occupancy and energy use. They may not reflect how energy is consumed by the people living at the property.

## Improve this property's energy performance

By following our step by step recommendations you could reduce this property's energy use and potentially save money.

Carrying out these changes in order will improve the property's energy rating and score from F (23) to B (86).

Step	Typical installation cost	Typical yearly saving
1. Cavity wall insulation	£500 - £1,500	£186
2. Internal or external wall insulation	£4,000 - £14,000	£414
3. Floor insulation (solid floor)	£4,000 - £6,000	£134
4. Add additional 80 mm jacket to hot water cylinder	£15 - £30	£30
5. Low energy lighting	£35	£34
6. Gas condensing boiler	£3,000 - £7,000	£915
7. Solar water heating	£4,000 - £6,000	£34
8. Solar photovoltaic panels	£3,500 - £5,500	£395

## Paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme](https://www.gov.uk/guidance/check-if-you-may-be-eligible-for-the-boiler-upgrade-scheme-from-april-2022). This will help you buy a more efficient, low carbon heating system for this property.

[Find energy grants and ways to save energy in your home](https://www.gov.uk/improve-energy-efficiency).

---

## Estimated energy use and potential savings

Estimated yearly energy cost for this property	£2253
--	-------

---

Potential saving	£1747
------------------	-------

---

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the people living at the property.

The potential saving shows how much money you could save if you [complete each recommended step in order](#).

For advice on how to reduce your energy bills visit [Simple Energy Advice](#) (<https://www.gov.uk/improve-energy-efficiency>).

---

## Heating use in this property

Heating a property usually makes up the majority of energy costs.

## Estimated energy used to heat this property

Type of heating	Estimated energy used
-----------------	-----------------------

Space heating	8455 kWh per year
---------------	-------------------

---

Water heating	1994 kWh per year
---------------	-------------------

## Potential energy savings by installing insulation

Type of insulation	Amount of energy saved
--------------------	------------------------

Cavity wall insulation	909 kWh per year
------------------------	------------------

---

Solid wall insulation	2027 kWh per year
-----------------------	-------------------

---

## Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

### Assessor contact details

Assessor's name	Jason Franklin
Telephone	023 8022 1188
Email	<a href="mailto:legal@franklinallan.co.uk">legal@franklinallan.co.uk</a>

### Accreditation scheme contact details

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor ID	EES/004368
Telephone	01455 883 250
Email	<a href="mailto:enquiries@elmhurstenergy.co.uk">enquiries@elmhurstenergy.co.uk</a>

### Assessment details

Assessor's declaration	No related party
Date of assessment	23 September 2022
Date of certificate	26 September 2022
Type of assessment	<a href="#">RdSAP</a>

---